

**7835.5000 SEPARATE DISTRIBUTION TRANSFORMER.**

The utility may require a separate distribution transformer for the qualifying facility if necessary either to protect the safety of employees or the public or to keep service to other customers within prescribed limits.

**Statutory Authority:** *MS s 216A.05; 216B.08; 216B.164*

**History:** *9 SR 993*

**Published Electronically:** *February 28, 2000*